

# Skyline Mountain Resort

## Fire Pit Approval Form

Name: \_\_\_\_\_

Lot Number: \_\_\_\_\_

### OPEN FIRES:

All open fires in SMR must be in fire pits that have been approved by a member of SMR'S Fire Committee. The following requirements must be met:

1. Fire rings must consist of masonry or steel construction; with the opening at a minimum of 24" to a maximum of 48", with a minimum depth of 18" and not to extend above the ground more than 24" and with a minimum of 4" of coarse gravel or refractory, lining the base of the ring.
2. Area surrounding the outside edge of the fire ring shall be void of any flammable vegetation or other combustible material to a minimum radius of 15' horizontally. Vertical clearance of combustible materials and flammable vegetation shall be at a minimum of 15'.
3. The fire must be attended at all times or until it is entirely extinguished.
4. The following are recommended safety tips, that should be adhered to:
  - a. Water or a fire extinguisher readily available.
  - b. Spark screen to cover fire pit.
  - c. Fire wood shall be safely stored away from the fire pit, buildings and structures.

APPROVED \_\_\_\_\_

REJECTED \_\_\_\_\_

FIRE COMMITTEE APPROVAL \_\_\_\_\_

DATE \_\_\_\_\_